

Mail Two Copies to:
DEPARTMENT OF PUBLIC HEALTH
3575 11th Street (P.O. Box 1370)
Riverside, California 92502

WATER WELL DRILLERS REPORT

(County Ordinances No. 340 and 340A)
COUNTY OF RIVERSIDE
DEPARTMENT OF PUBLIC HEALTH

06940

Do Not Fill In

State Well No.
Other Well No.
Region.

(1) OWNER: IBRAHIM

Name Ribbonwood Ranch
Address Box 34 A
Mountain Center, Calif.

(2) LOCATION OF WELL:

County Riverside Owner's number, if any
Township, Range, and Section NW 1/4 NW 1/4 Sec 9 T6S R4E
Distance from cities, roads, railroads, etc. 1 mi. W, 1 mi. N. of
Hyw 71 & 74 junctions

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Destroying ☐
If destruction, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) EQUIPMENT:

Rotary air ☒
Cable ☐
Other ☐

(6) CASING INSTALLED:

STEEL: OTHER:
SINGLE ☐ DOUBLE ☐

If gravel packed

From ft.	To ft.	Diam. ft.	Gage or Wall ft.	Diameter of Bore ft.	From ft.	To ft.
0	445	6 5/8	188	9"	0	445

Size of shoe or well ring:

Size of gravel: Pea Rock

Describe joint Arc Weld

(7) PERFORATIONS OR SCREEN:

Type of perforation or name of screen

From ft.	To ft.	Perf. per row	Rows per ft.	Size in. x in.
205	445	6	4	3 1/2 X 1/8

(8) CONSTRUCTION:

Was a surface sanitary seal provided? Yes ☒ No ☐ To what depth 20 ft.

Were any strata sealed against pollution? Yes ☐ No ☒ If yes, note depth of strata

From ft. to ft.

From ft. to ft.

Method of sealing Puddle Clay & Cement

(9) WATER LEVELS:

Depth at which water was first found, if known 175 ft.

Standing level before perforating, if known ft.

Standing level after perforating and developing 150 ft.

(10) WELL TESTS: Air Test Only

Was pump test made? Yes ☐ No ☒ If yes, by whom?

Yield: 110 gal./min. with ft. drawdown after hrs.

Temperature of water cold Was a chemical analysis made? Yes ☐ No ☒

Was electric log made of well? Yes ☐ No ☒ If yes, attach copy

(11) WELL LOG:

Total depth 445 ft. Depth of completed well 445 ft.

Formation: Describe by color, character, size of material, and structure

ft. to ft.

0 - 80	Grey DG
80 - 82	Brown Clay
82 - 85	Colored Gravel
85 - 92	Grey DG
92 - 94	Colored Gravel
94 - 200	Grey DG
200 - 280	Layers of Grey DG and colored gravel
280 - 290	Black & Green Rock
290 - 405	Layers of Grey DG & colored gravel
405 - 406	Black rock & clay
406 - 445	Grey sand & colored gravel

Pump level 315 - 100 GPM

Work started 9 - 1 1976, Completed 9 - 7 1976

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ivan D. Alexander

(Person, firm, or corporation) (Typed or printed)

Address P.O. Box 71

Anza, Calif. 92306

[SIGNED]

Dennis J. Law
(Well Driller)

License No. 166271

Dated 9-7, 19 76

SKETCH LOCATION OF WELL ON REVERSE SIDE

WELL LOCATION SKETCH

RECEIVED


OCT 1 - 1976

RIVERSIDE CO.
HEALTH DEPT.
Environmental Health


Township 6 N/S

Range 4 E/W

Section No. 9



- A. Location of well in sectionized areas.
Sketch roads, railroads, streams, or other features as necessary.



- B. Location of well in areas not sectionized.
Sketch roads, railroads, streams, or other features as necessary.
Indicate distances.